



Product Service

Attestation of Conformity

No. N8A 077323 0084 Rev. 03

Holder of Certificate: **CECEP Solar Energy
Technology (Zhenjiang) Co., Ltd.**
No. 9, Beishan Road, XinQu
212132 Zhenjiang, Jiangsu Province
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic
(PV) Modules**
**Mono-crystalline Silicon Photovoltaic (PV)
Modules**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. For details see: www.tuvsud.com/ps-cert

Test report no.: 882161721205

Date, 2021-07-08


(Xinlian LUO)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.



Attestation of Conformity

No. N8A 077323 0084 Rev. 03

Model(s):

1000V modules:

With 6" mono c-Si cells:

CEC6-72-xxxM (xxx=320-375, in steps of 5, 72 cells)

CEC6-60-xxxM (xxx=270-310, in steps of 5, 60 cells)

With 1/2 cut 6" mono c-Si cells:

CEC6-72-xxxMH (xxx=350-460, in steps of 5, 144 cells)

CEC6-60-xxxMH (xxx=295-385, in steps of 5, 120 cells)

With 182mm 1/2 cut mono c-Si cells:

CEC6-72-xxxMH (xxx=530-550, in steps of 5, 144 cells)

CEC6-66-xxxMH (xxx=490-500, in steps of 5, 132 cells)

CEC6-60-xxxMH (xxx=445-455, in steps of 5, 120 cells)

CEC6-54-xxxMH (xxx=400-410, in steps of 5, 108 cells)

1500V modules:

With 6" mono c-Si cells:

CEC6-72-xxxMV (xxx=320-375, in steps of 5, 72 cells)

CEC6-60-xxxMV (xxx=270-310, in steps of 5, 60 cells)

With 1/2 cut 6" mono c-Si cells:

CEC6-72-xxxMHV (xxx=350-460, in steps of 5, 144 cells)

CEC6-60-xxxMHV (xxx=295-385, in steps of 5, 120 cells)

With 182mm 1/2 cut mono c-Si cells:

CEC6-72-xxxMHV (xxx=530-550, in steps of 5, 144 cells)

CEC6-66-xxxMHV (xxx=490-500, in steps of 5, 132 cells)

CEC6-60-xxxMHV (xxx=445-455, in steps of 5, 120 cells)

CEC6-54-xxxMHV (xxx=400-410, in steps of 5, 108 cells)

Bifacial modules with 166mm 1/2 cut mono c-Si cells:

CEC6-72-xxxMDHV (xxx=380-450, in steps of 5, 144 cells)

CEC6-60-xxxMDHV (xxx=320-375, in steps of 5, 120 cells)

CEC6-48-xxxMDHV (xxx=255-300, in steps of 5, 96 cells)

CEC6-36-xxxMDHV (xxx=190-225, in steps of 5, 72 cells)

Bifacial modules with 182mm bifacial 1/2 cut mono c-Si cells:

CEC6-72-xxxMDHV (xxx=525-550, in steps of 5, 144 cells)

CEC6-66-xxxMDHV (xxx=485-500, in steps of 5, 132 cells)

CEC6-60-xxxMDHV (xxx=440-455, in steps of 5, 120 cells)

CEC6-54-xxxMDHV (xxx=395-410, in steps of 5, 108 cells)

xxx is standing for rated output power at STC

Parameters:

Construction: Framed, with Junction box, cable and connector.

Test Laboratory: Yangzhou Opto-electrical product testing institute

(10 Kaifa West Rd., Yangzhou Jiangsu, P. R. China 225009)

Safety Class: Class II

Max. System Voltage: 1000V DC or 1500V DC

Fire Safety Class: Class C according to UL790

Tested

EN IEC 61730-1:2018

EN IEC 61730-2:2018

according to:

EN IEC 61730-1:2018/AC:2018-06

EN IEC 61730-2:2018/AC:2018-06